


Model MFD-31


Performance Data

PRESSURE DROP



The pressure drop information is obtained by testing a 36"x 36" damper in accordance with Standard 500 per figure 5.3(in duct). Blades are positioned at 90 degrees full open.

LEAKAGE CHART



The leakage information is obtained by testing a 36"x 36" damper with optional blade edge and stainless steel side seals in accordance with Standard 500 per figure 5.5(in wall). Holding torque applied is 5in./lbs. per square foot of damper area.